

**DECLARATION OF CONFORMITY**  
**The Pressure Equipment Directive 97/23/EC**



<b>Name and Address of Manufacturer within the European Community</b>	
Virginia KMP Ltd Cortonwood Drive Cortonwood Business Park Brampton Barnsley United Kingdom	
<b>Description of Pressure Equipment</b>	
K Line Filter Driers for refrigerant plants Types:- VS 48, VS 96, VS 144 & VS 192	
<b>Net Volume (Maximum)</b>	
VS 48 Series: 2.69 Ltrs (0.72 US gals)	VS 92 Series: 4.21 Ltrs (1.13 US gals)
VS 144 Series: 5.69 Ltrs (1.53 US gals)	VS 192 Series: 7.20 Ltrs (1.93 US gals)
<b>Classified for</b>	Fluid Group 2 (non-toxic and non-flammable refrigerants)
<b>Min / Max allowable working temperature</b>	-40°C to 80°C (-40°F to 248°F)
<b>Maximum working pressure</b>	35 bar (514 psig) for VS 48, 96 & 144. 28 bar (411.6 psig) for VS 192

**Conformity and Assessment Procedure followed**

	Type	Max Working Pressure (bar)	Max net volume (Ltr)	Category	Module
FLUID GROUP 2	VS 48	35	2.69	1	D1
	VS 96	35	4.21	1	D1
	VS 144	35	5.69	1	D1
	VS 192	28	7.20	2	D1

**References of Technical Standards and Specifications used**

CE marked under approval of LRQA as the notified body (0038)

**Authorised person for the manufacturer within the European Community**

**Name:** Kenny Adamson      **Title:** Managing Director

**Signature:**

**March 14 2002**